

This report shall not be reproduced, except in full without the written approval of TCWDWL/TCWDWL/QF-BRES

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612
Certified correct by:

ERIEL MAY B. BARAO
Chemist/ Section Manager
PRC License No.: 11486

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Checked by:

Analysis conducted by:

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010
Standard methods for the examination of Water and Wastewater, 23rd Edition

REFERENCES:

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

Result of examination specifically relates to samples as received.
Samples exceeds the recommended SMEWW Temperature requirements, as such please interpret Results with caution. Sample must be kept at less than 10 °C but not frozen. SMEWW 9060 Microbiological Sample and Storage

REMARKS:

SMEWW 9215B Pour Plate Method for the determination of HPC, 35 °C / 48H, Plate Count Agar

SMEWW 9221 Multiple Tube Fermentation Technique, for the determination of total and thermotolerant coliforms

TEST METHOD USED:

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample		Sampling Date and Time				Results of Analysis	
	Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform (MPN/100 ml)	HPC (CFU/ml)	
Sample Lab No. B19-3558/ Address PUELAY ZONE 7 BLOW OFF Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	9:20 am	12:04 pm	1:00 pm	<1.1	<1.1	<1	
Sample Lab No. B19-3559/ Address PUELAY DIEGO BLOW OFF Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	9:30 am	12:04 pm	1:00 pm	<1.1	<1.1	<1	
Sample Lab No. B19-3560/ Address PUELAY DIEGO BLOW OFF Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	9:38 am	12:04 pm	1:00 pm	<1.1	<1.1	20	
Sample Lab No. B19-3561/ Address BARANGOBONG LOPEZ Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	9:45 am	12:04 pm	1:00 pm	<1.1	<1.1	25	
Sample Lab No. B19-3562/ Address AMAMPerez MABURAC Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	9:56 am	12:04 pm	1:00 pm	<1.1	<1.1	6	
Sample Lab No. B19-3563/ Address AMAMPerez RIVERSIDE Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	10:00 am	12:04 pm	1:00 pm	<1.1	<1.1	3	
Sample Lab No. B19-3564/ Address AMAMPerez XONE V Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	10:10 am	12:04 pm	1:00 pm	<1.1	<1.1	5	
Sample Lab No. B19-3565/ Address AMAMPerez ZONE VI Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	10:20 am	12:04 pm	1:00 pm	<1.1	<1.1	31	
Sample Lab No. B19-3566/ Address AMAMPerez BAPTIST Sampling Pt. TAP/ 100cc/Clear/In Sterilized Bottle	12/11/19	10:30 am	12:04 pm	1:00 pm	<1.1	<1.1	22	
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard								
<500								

Name of Sampler: PABLO RAGASA

Address: POBLACION ZONE 1, VILLASIS PANGASINAN

Sample Temp upon receipt: 26.2 °C

Time Reported: 9:03:53 AM