

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-3655/ Address PIAZ - BOUNDARY BLOW Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	9:44 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-3656/ Address PIAZ - ZONE VII - Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	10:00 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-3657/ Address CARAMUTAN LIBTONG II Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	10:15 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-3658/ Address CARAMUTAN LIBTONG I Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	10:26 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-3659/ Address LIPAY AMBOKLAO BLOW Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	10:30 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-3660/ Address LIPAY HALOG FAMILY Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	10:40 am	12:57 pm	1:00 pm	<1.1	<1.1	31
Sample Lab No. B18-3661/ Address PUELAY LEFT Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	10:50 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-3662/ Address V.W.D OFFICE FAUCET Sampling Pt. TAP/	100cc/Clear/in Sterilized Bottle	12/12/18	11:00 am	12:57 pm	1:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard								
<500	<1.1	<1.1						

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:


Standard method for the examination of Water and Wastewater, 23rd Edition  
 Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010  
 For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON  
 Medical Technologist  
 PRC License No.: 0081808

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Certified correct by:  
  
 LAZA DIANNE M. DE LEON  
 Head of Laboratory  
 PRC License No.: 51612