

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform E. Coli (CFU/ml)	HPC
Sample Lab No. B19-0440/ Address PIAZ - BOUNDARY Sampling Pt. TAP/ ASINGAN BLOW OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	8:23 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0441/ Address PIAZ - GAWAD KALINGA Sampling Pt. TAP/ BLOW OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	8:35 am	11:39 am	1:00 pm	<1.1	<1.1	41
Sample Lab No. B19-0442/ Address CARAMUTAN FABRO Sampling Pt. TAP/ BLOW OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	8:45 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0443/ Address CARAMUTAN LIBTONG I Sampling Pt. TAP/ BLOW OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	9:00 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0444/ Address LIPAY - AMBOKLAO BLOW Sampling Pt. TAP/ OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	9:20 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0445/ Address LIPAY - UPPER DIKE BLOW Sampling Pt. TAP/ OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	9:40 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0446/ Address PUELAY WEST BLOW OFF Sampling Pt. TAP/ OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	10:00 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0447/ Address PUELAY IRAQ BLOW OFF Sampling Pt. TAP/ OFF	100cc/Clear/ In Sterilized Bottle	2/12/19	10:19 am	11:39 am	1:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard								
<500	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition  
 Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010  
 For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

**DENISSA ANNE G. AYSON**  
 Medical Technologist  
 PRC License No.: 0081806

Certified correct by:

**LAIZA DIANNE M. DE LEON**  
 Head of Laboratory  
 PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016