



# TARLAC CITY WATER DISTRICT WATER LABORATORY

UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



**ACCREDITATION NUMBER: 03-004-19-LW-1**

*TCWDWL/QF-BRES-19-01-0000051*

*TCWDWL/QF-BRS-19-01-006*

*TCWDWL/QF-BRO-19-01-0000048*

## BACTERIOLOGICAL WATER ANALYSIS

**Requesting Agency/Client:** VILLASIS WATER DISTRICT

Date Reported: 01/22/2019

**Address:** POBLACION ZONE 1, VILLASIS PANGASINAN

Time Reported: 10:25:05 AM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-0191/ Sampling Pt. TAP/ Address SAN NICOLAS BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:00 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0192/ Sampling Pt. TAP/ Address BACAG PURINA BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:10 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0193/ Sampling Pt. TAP/ Address BACAG I.P.I BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:15 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0194/ Sampling Pt. TAP/ Address BACAG HONEYMOON BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:20 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0195/ Sampling Pt. TAP/ Address BACAG WEST LAVISTE BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:30 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0196/ Sampling Pt. TAP/ Address BACAG WEST ELEM SCHOOL BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:40 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0197/ Sampling Pt. TAP/ Address TOMBOD ZONE II BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	8:50 am	11:33 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0198/ Sampling Pt. TAP/ Address TOMBOD ZONE IV BLOW OFF	100cc/Clear/In Sterilized Bottle	1/15/19	9:10 am	11:33 am	1:00 pm	<1.1	<1.1	<30
<b>Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard</b>						<1.1	<1.1	<500

**TEST METHOD USED:**

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

**REMARKS:**

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

**REFERENCES:**

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON

Certified correct by: