



**TARLAC CITY WATER DISTRICT  
WATER LABORATORY**  
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



**ACCREDITATION NUMBER: 03-004-19-LW-1**

*TCWDWL/QF-BRES/-19-03-0000205*

*TCWDWL/QF-BRS/-19-03-004*

*TCWDWL/QF-BRO/-19-03-0000202*

**BACTERIOLOGICAL WATER ANALYSIS**

**Requesting Agency/Client: VILLASIS WATER DISTRICT**

Date Reported: 03/18/2019

**Address: POBLACION ZONE 1, VILLASIS PANGASINAN**

Time Reported: 1:44:49 PM

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/ E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B19-0759/ Sampling Pt. TAP/ Address BARRACA PUNTA HOMES BLOW OFF	100cc/Clear/In Sterilized Bottle	3/11/19	9:40 am	12:51 pm	1:00 pm	<1.1	<1.1	39
Sample Lab No. B19-0760/ Sampling Pt. TAP/ Address PUELAY ZONE VII BLOW OFF	100cc/Clear/In Sterilized Bottle	3/11/19	10:00 am	12:51 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0761/ Sampling Pt. TAP/ Address PUELAY IRAQ BLOW OFF	100cc/Clear/In Sterilized Bottle	3/11/19	10:10 am	12:51 pm	1:00 pm	<1.1	<1.1	42
Sample Lab No. B19-0762/ Sampling Pt. TAP/ Address PUELAY DIEGO FAMILY BLOW OFF	100cc/Clear/In Sterilized Bottle	3/11/19	10:20 am	12:51 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B19-0763/ Sampling Pt. TAP/ Address POBLACION ZONE II BLOW OFF	100cc/Clear/In Sterilized Bottle	3/11/19	10:30 am	12:51 pm	1:00 pm	<1.1	<1.1	47
Sample Lab No. B19-0764/ Sampling Pt. TAP/ Address POBLACION ZONE II DON RAMON BLOW OFF	100cc/Clear/In Sterilized Bottle	3/11/19	10:40 am	12:51 pm	1:00 pm	<1.1	<1.1	49
Sample Lab No. B19-0765/ Sampling Pt. TAP/ Address POBLACION ZONE V IDEAL HOMES FAUCET	100cc/Clear/In Sterilized Bottle	3/11/19	10:50 am	12:51 pm	1:00 pm	<1.1	<1.1	60
Sample Lab No. B19-0766/ Sampling Pt. TAP/ Address POBLACION ZONE I - BAGSAKAN FAUCET	100cc/Clear/In Sterilized Bottle	3/11/19	11:00 am	12:51 pm	1:00 pm	<1.1	<1.1	44
<b>Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard</b>						<1.1	<1.1	<500

**TEST METHOD USED:**

**SMEWW 9221 Multiple Tube Fermentation Technique with HPC**, for the determination of total and thermotolerant coliforms/E. Coli

**SMEWW 9215B Pour Plate Method** for the determination of HPC

**REMARK/S:**

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

**REFERENCES:**

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

**DENISSA ANNIE G. AYSON**

Certified correct by:

**LAIZA DIANNE M. DE LEON**