



UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

TCWDL/QF-BRES-18-10-0000825
TCWDL/QF-BRS-18-10-003/004
TCWDL/QF-BRO-18-10-0000809

Date Reported:	10/16/2018
Time Reported:	8:55:12 AM

Address

Time Reported: 8:55:12 AM

Sample ID (Lab. No., Sampling Point, Address)		Physical Characteristics of Water Sample		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-2966/ Address SLABA - LOMBOY Sampling Pt. TAP/ 100cc/Clear/in		Sterilized Bottle		10/9/18	9:28 am	12:34 pm	1:00 pm	<1.1	<1.1	82
Sample Lab No. B18-2969/ Address SLABA - LOMBOY Sampling Pt. TAP/ 100cc/Clear/in		Sterilized Bottle		10/9/18	10:00 am	12:34 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2970/ Address BACAG - PURINA Sampling Pt. TAP/ 100cc/Clear/in		Sterilized Bottle		10/9/18	10:12 am	12:34 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2971/ Address BACAG - I.P.I. - BOUNDARY URDANETA Sampling Pt. TAP/ 100cc/Clear/in		Sterilized Bottle		10/9/18	10:25 am	12:34 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2972/ Address BACAG - HONEYMOON Sampling Pt. TAP/ 100cc/Clear/in		Sterilized Bottle		10/9/18	10:35 am	12:34 pm	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2973/ Address BACAG - TOMBOY Sampling Pt. TAP/ 100cc/Clear/in		Sterilized Bottle		10/9/18	10:45 am	12:34 pm	1:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard										
<500										
<1.1										
<1.1										

Certified correct by
 LAIZA DIANNE M. DE LEON
 Head of Laboratory
 PRC License No.: 51612

PrimeWater Tarlac City
Pages 1 of 2

Not Valid Without Dry Seal
Revision 1, Effective: 4 September 2017
Original Issue 10 May 2016

910

Pages 1 of 2



UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.

ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL:OF-BRES:18-10-0000880

TCWDW/OE-BRS-18-10-011

ICWDM/OF-BRO-18-10-0000864

Date Reported: 10/31/2018

BACTERIOLOGICAL WATER ANALYSIS

Requesting Agency/client: VILLASIS WATER DISTRICT

POBLACION ZONE 1, VILLAS PANGASINAN

Address:

[illegible]

TEST METHOD USED:

SRENN 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMENW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippines National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010
For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by

Medical Technology
PRC License No.: 0081806

Head of Laboratory
LISA DIANNE M. DE LEON
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

PrimeWater Tarlac City

Revision 1, Effective: 4 September 2017
Original Issue 10 May 2016

Santa Rosa Road, Brgy. Maliwalò, Tarlac City, Tarlac (045) 982-0956; 982-1059; 982-1059; 982-1059; 982-1059