



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1
TCWDWL/QF-BRES-18-11-000942

TCWDWL/QF-BRS-18-11-005

TCWDWL/QF-BRO-18-11-000927

Date Reported: 11/21/2018

Time Reported: 3:31:53 PM

POBLACION ZONE 1, VILLASIS PANGASINAN

Testing Agency/client: VILLASIS WATER DISTRICT

BACTERIOLOGICAL WATER ANALYSIS

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform E. Coli (MPN/100 ml)	HPC (CFU/ml)
Lab No. B18-3342 / Drinking Pt. TAP / 555 SLABA - SAN NICOLAS	Sterilized Bottle	11/14/18	10:11 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3343 / Drinking Pt. TAP / 555 BACAG - PURINA	Sterilized Bottle	11/14/18	10:32 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3344 / Drinking Pt. TAP / 555 BACAG - I.P.I.	Sterilized Bottle	11/14/18	10:42 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3345 / Drinking Pt. TAP / 555 BACAG HONENMOON	Sterilized Bottle	11/14/18	10:52 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3346 / Drinking Pt. TAP / 555 BACAG WEST BAGAYAN	Sterilized Bottle	11/14/18	11:00 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3347 / Drinking Pt. TAP / 555 BACAG LAVISTE BLOW	Sterilized Bottle	11/14/18	11:10 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3348 / Drinking Pt. TAP / 555 PUELAY ZONE VII BLOW	Sterilized Bottle	11/14/18	11:20 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
Lab No. B18-3349 / Drinking Pt. TAP / 555 AZON CARWASH - PUELAY	Sterilized Bottle	11/14/18	11:25 am	1:08 pm	2:00 pm	<1.1	<1.1	<30
One National Standards for Drinking Water 2017 and AO 2017-0010 Standard								
<1.1								
<500								

METHOD USED:

MEW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

MEW 9215B Pour Plate Method for the determination of HPC

MARKS:

result of examination specifically relates to samples as received.

the water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

RENCES:

standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

r Hemodialysis Water-Department of Health Order No 2012-0001

sis conducted by

DENISSA ANNE G. AYSON

Medical Technologist

PRC License No. 0081806

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

PrimeWater Tarlac City

Certified/correct by:
LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No. 51612