

EOD-LAB-011-1
 Paid per OR # 485652
 Amount: Php 3,240.00

Engr. Adelfor Valle
 General Manager

Noted by: *[Signature]*
 9/23/2019

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Maelyn S. Vintuan, RMT, RN, MPH
 Quality Control Assurance Officer
 WMLA - 12 - 0229
 9/23/2019

Analyst:

Sample Type	Total Coliform (MPN/100ml)	Thermotolerant Coliform (MPN/100ml)	HPC (CFU/ml)
Treated Water	less than 1.1	less than 1.1	less than 500
Untreated Water	-	-	-

Certified Correct

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Result of examination specifically related to samples as received

NOTE:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

LEGEND:

Source/Location	Date/Time Collected	Physical Characteristics	Total Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU / ml) (Pour Plate)	REMARK(S)
Amamperez Maburac Blow Off (3960)	Sept. 17, 2019 /11:17 AM	Colorless Clear	< 1.1	< 1.1	8	PASSED

RESULTS OF BACTERIOLOGICAL ANALYSIS

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WVD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WVD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

RESULTS OF BACTERIOLOGICAL ANALYSIS

Source/Location	Date/Time Collected	Physical Characteristics	Total Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU / ml) (Pour Plate)	REMARK(S)
Amamperes Riverside Blow Off (3961)	Sept. 17, 2019 / 11:27 AM	Colorless	< 1.1	< 1.1	1	PASSED

LEGEND:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

NOTE:

Result of examination specifically related to samples as received

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Treated Water	less than 1.1	less than 1.1	less than 500
Untreated Water	-	-	less than 1.1

Analyst:

Maelyn S. Vinluan, RMT, RN, MPH
 9/27/2019
 Quality Control Assurance Officer
 WMLA - 12 - 0229

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Noted By: *[Signature]*
 Engr. Adelfo B. Valle
 General Manager
 9/27/2019

Paid per OR # 4856520
 Amount: Php 3,240.00
 EOD-LAB-011-1

Client: VILLASIS WATER DISTRICT
 Address: Villasias, Pangasinan
 Source: WVD Water
 Analysis Requested: Bacteriological Analysis
 Date Analyzed: September 17, 2019
 Specimen Submitted by: Pablo Ragasa

RESULTS OF BACTERIOLOGICAL ANALYSIS

Source/Location	Date/Time Collected	Physical Characteristics	Total Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU / ml) (Four Plate)	PASSED
Amamperez Zone V Blow Off (3962)	Sept. 17, 2019 /11:45 AM	Colorless Clear	< 1.1	< 1.1	5	PASSED

LEGEND:
 Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

NOTE: Result of examination specifically related to samples as received.

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Treated Water	less than 1.1	less than 1.1	less than 500
Untreated Water	-	less than 1.1	-

Analyst: Certified Correct:

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Maelyn S. Vinluan, RMT, RN, MPH
 Quality Control Assurance Officer
 WMLA - 12 - 0229

Noted by: Engr. Adelfor Valle
 General Manager

Paid per OR # 4856520
 Amount: Php 3,240.00
 EOD-LAB-011-1

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WVD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

RESULTS OF BACTERIOLOGICAL ANALYSIS

Source/Location	Date/Time Collected	Physical Characteristics	Total Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU / ml) (Four Plate)	REMARK(S)
Amamperez Ruiz Blow Off (3963)	Sept. 17, 2019 / 11:58 AM	Colorless	< 1.1	< 1.1	1	PASSED

LEGEND:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

NOTE:

Result of examination specifically related to samples as received.

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Analyst:	Maelyn S. Vinluan, RMT, RN, MPH 9/23/19
Total Coliform (MPN/100ml)	less than 1.1
Thermotolerant Coliform (MPN/100ml)	less than 1.1
HPC (CFU/ml)	less than 500
Treated Water	less than 1.1
Untreated Water	less than 1.1

Certified Correct

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Quality Control Assurance Officer
 WMLA - 12 - 0229

Noted by: *[Signature]*
 Engr. Adolfo B. Valle
 General Manager

Paid per OR # 4856524
 Amount: Php 3,240.00
 EOD-LAB-011-1

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WWD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

RESULTS OF BACTERIOLOGICAL ANALYSIS

Source/ Location	Date/Time Collected	Physical Characteristics	Total Coliform(MPN/ 100 ml)(Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN/ 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU/ ml) (Pour Plate)	REMARK(S)
Amamperez Zone VI Blow Off (3964)	Sept. 17, 2019 /12:12 PM	Colorless	< 1.1	< 1.1	1	PASSED

LEGEND:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

NOTE:

Result of examination specifically related to samples as received

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Thermotolerant Coliform (MPN/100ml.)	less than 1.1
HPC (CFU/ml.)	less than 1.1
Total Coliform (MPN/100ml.)	less than 1.1
	less than 500

Treated Water
 Untreated Water

Certified Correct:

Analyst:

Maelyn S. Vinluan, RMT, RN, MPH
 Quality Control Assurance Officer
 WMLA - 12 - 0229

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Noted by: Engr. Adelfo B. Valle
 General Manager

Paid per OR # 4856529
 Amount: Pp 3,240.00
 EOD-LAB-011-1

Health Is Wealth

EOD-LAB-011-1
 Amount: Php 3,240.00
 Paid per OR # 4856529

Engr. Adelfor Valle
 General Manager

Noted by: *[Signature]*
 9/23/19

Sheldon Steven C. Aquino, MD, FSP
 Head, Laboratory

[Signature]

Maelyn S. Vinluan, RMT, RN, MPH
 Quality Control Assurance Officer

WMLA - 12 - 0229

Analyst:

Untreated Water	Total Coliform (MPN/100ml)	HPC (CFU/ml)
-	less than 1.1	less than 1.1
-	less than 1.1	less than 1.1
Treated Water	Thermotolerant Coliform (MPN/100ml)	
-	less than 1.1	
-	less than 500	

Certified Correct

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Result of examination specifically related to samples as received

NOTE:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

LEGEND:

Source/ Location	Date/Time Collected	Physical Characteristics	Total Coliform(MPN/ 100 ml)(Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU / ml) (Pour Plate)	REMARK(S)
Barangobong Lopez Compound I (3965)	Sep. 17, 2019 /12:30 PM	Colorless	< 1.1	< 1.1	3	PASSED

RESULTS OF BACTERIOLOGICAL ANALYSIS

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WVD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WVD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

RESULTS OF BACTERIOLOGICAL ANALYSIS

Source/ Location	Date/Time Collected	Physical Characteristics	Total Coliform(MPN/100 ml)(Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU / ml) (Pour Plate)	REMARKS(S)
Barangobong Lopez Compound II (3966)	Sept. 17, 2019 /12:35 PM	Colorless	< 1.1	< 1.1	8	PASSED

LEGEND:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012) , Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

NOTE:

Result of examination specifically related to samples as received

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Treated Water	less than 1.1	Total Coliform (MPN/100ml)
Untreated Water	less than 1.1	Thermotolerant Coliform (MPN/100ml)
	less than 500	HPC (CFU/ml)

Analyst:

Maelyn S. Vinluan, RMT, RN, MPH
 Quality Control Assurance Officer
 WMLA - 12 - 0229
 Date: 9/22/2019

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Noted by: *Engr. Adelfob. Valle*
 General Manager
 Date: 9/22/2019

Paid per OR # 485652.
 Amount: Php 3,240.00
 EOD-LAB-011-1

EOD-LAB-011-1
 Paid per OR # 4856529
 Amount: Php 3,240.00

Noted by: Engr. Alberto Valle
 General Manager
 or Ma. 9/22/19

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

Maelyn S. Vinluan, RMT, RN, MPH
 Quality Control Assurance Officer
 WMLA - 12 - 0229
 9/23/2019

Analyst:

Treated Water	Total Coliform (MPN/100ml)	less than 1.1
Untreated Water	Thermotolerant Coliform (MPN/100ml)	less than 1.1
	HPC (CFU/ml)	less than 500
		less than 1.1

Certified Correct

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Result of examination specifically related to samples as received

NOTE:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for the Water 2017 (PNSDW 2017).

LEGEND:

Source/Location	Date/Time Collected	Physical Characteristics	Total Coliform(MPN/100 ml)(Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN / 100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU/ml) (Pour Plate)	REMARKS(S)
Fueyay Zone 7 Blow Off (3967)	Sept. 17, 2019 /12:50 PM	Colorless Clear	< 1.1	< 1.1	2	PASSED

RESULTS OF BACTERIOLOGICAL ANALYSIS

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WWD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa

EOD-LAB-011-1
 Paid per OR # 4856524
 Amount: Php 3,240.00

General Manager

Engr. Adelfo Valle

Noted by: *[Signature]*

WMLA - 12 - 0229

Quality Control Assurance Officer

Maelyn S. Vinluan, RMT, RN, MPH

[Signature] 9/22/2019

Sheldon Steven C. Aquino, MD, FPSP
 Head, Laboratory

[Signature]

Certified Correct:

Analyst:

Total Coliform (MPN/100ml)
 Thermotolerant Coliform (MPN/100ml)
 HPC (CFU/ml)

Treated Water
 less than 1.1
 less than 1.1
 less than 500

Untreated Water
 -
 less than 1.1
 -

REFERENCE VALUE: PNSDW 2017 (AO 2017-0010)

Result of examination specifically related to samples as received

NOTE:

Test method used a/= Multiple Tube Fermentation Technique, Standard Methods for the Examination of Water and Wastewater, 22nd (2012), Philippine National Standards for Drinking Water 2017 (PNSDW 2017).

LEGEND:

Source/Location	Date/Time Collected	Physical Characteristics	Total Coliform (MPN/100 ml) (Multiple Tube Fermentation Mtd.)	Thermotolerant Coliform (MPN/100 ml) (Multiple Tube Fermentation Mtd.)	Heterotrophic Plate Count (CFU/ml) (Four Plate)	REMARK(S)
Pueyay Marcoz Blow Off (3968)	Sept. 17, 2019 1:03 PM	Colorless	< 1.1	< 1.1	3	PASSED

RESULTS OF BACTERIOLOGICAL ANALYSIS

Client : VILLASIS WATER DISTRICT
 Address : Villasias, Pangasinan
 Source : WVD Water
 Analysis Requested : Bacteriological Analysis
 Date Analyzed : September 17, 2019
 Specimen Submitted by : Pablo Ragasa