



**TARLAC CITY WATER DISTRICT
WATER LABORATORY**
UNDER THE MANAGEMENT OF THE PRIMEWATER INFRASTRUCTURE CORP.



ACCREDITATION NUMBER: 03-0003-16-LW-1

TCWDWL/QF-BRES-18-09-0000737

TCWDWL/QF-BRS-18-09-004

TCWDWL/QF-BRO-18-09-0000721

BACTERIOLOGICAL WATER ANALYSIS

Date Reported: 09/18/2018

Time Reported: 11:23:48 AM

Requesting Agency/Client: VILLASIS WATER DISTRICT

Address: POBLACION ZONE 1, VILLASIS PANGASINAN

Sample ID (Lab. No., Sampling Point, Address)	Physical Characteristics of Water Sample	Sampling Date and Time				Results of Analysis		
		Date	Collection	Receipt	Examination	Total Coliform (MPN/100 ml)	Thermotolerant Coliform/E. Coli (MPN/100 ml)	HPC (CFU/ml)
Sample Lab No. B18-2659/ Sampling Pt. TAP/ Address PIAZ BOUNDARY - ASINGAN BLOW OFF	100cc/Clear/In Sterilized Bottle	9/11/18	9:00 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2660/ Sampling Pt. TAP/ Address PIAZ BALETE - BLOW OFF	100cc/Clear/In Sterilized Bottle	9/11/18	9:10 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2661/ Sampling Pt. TAP/ Address PIAZ NAMNAMA - HOUSING BLOW OFF	100cc/Clear/In Sterilized Bottle	9/11/18	9:20 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2662/ Sampling Pt. TAP/ Address CARAMUTAN LIBTONG II	100cc/Clear/In Sterilized Bottle	9/11/18	9:30 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2663/ Sampling Pt. TAP/ Address CARAMUTAN LIBTONG I	100cc/Clear/In Sterilized Bottle	9/11/18	9:50 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2664/ Sampling Pt. TAP/ Address LIPAY AMBUKLAO - BLOW OFF	100cc/Clear/In Sterilized Bottle	9/11/18	10:00 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2665/ Sampling Pt. TAP/ Address LIPAY UPPER DIKE - BLOW OFF	100cc/Clear/In Sterilized Bottle	9/11/18	10:20 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Sample Lab No. B18-2666/ Sampling Pt. TAP/ Address SAN NICOLAS SLABA - BLOW OFF	100cc/Clear/In Sterilized Bottle	9/11/18	10:30 am	11:56 am	1:00 pm	<1.1	<1.1	<30
Philippine National Standards for Drinking Water 2017 and AO 2017-0010 Standard						<1.1	<1.1	<500

TEST METHOD USED:

SMEWW 9221 Multiple Tube Fermentation Technique with HPC, for the determination of total and thermotolerant coliforms/E. Coli

SMEWW 9215B Pour Plate Method for the determination of HPC

REMARKS:

Result of examination specifically relates to samples as received.

The water samples have complied with the standard values set by the PNSDW 2017 and AO 2017-010 for the parameters analyzed

REFERENCES:

Standard method for the examination of Water and Wastewater, 23rd Edition

Philippine National Standards for Drinking Water of 2017, Department of Health Administrative Order 2017-0010

For Hemodialysis Water-Department of Health Order No. 2012-0001

Analysis conducted by:

DENISSA ANNE G. AYSON
Medical Technologist
PRC License No.: 0081806

Certified correct by:

LAIZA DIANNE M. DE LEON
Head of Laboratory
PRC License No.: 51612

This report shall not be reproduced, except in full without the written approval of TCWDWL

TCWDWL/QF-BRES

Not Valid Without Dry Seal

Revision 1, Effective: 4 September 2017

Original Issue 10 May 2016

PrimeWater Tarlac City

Pages 1 of 1

Santa Rosa Road, Brgy. Maliwalo, Tarlac City, Tarlac (045) 982-0956; 982-1059; 491-0907; 982-1150