



Republic of the Philippines
Region I - Province of Pangasinan

Villasis Water District

(075) 632-1093 / (075) 632-1080 / 09178615250
www.villasiswaterdistrict.gov.ph * villasis_wd@yahoo.com
CCC # 95 * Poblacion Zone I, Villasis, 2427

EXCERPTS FROM THE MINUTES OF THE PRE-BID CONFERENCE FOR THE INFRASTRUCTURE PROJECT – EXPANSION OF 100MM PARALLEL PIPELINES IN BACAG WEST-HIGHWAY IN BARANGAY BACAG WEST, VILLASIS, PANGASINAN. ON THE 10TH DAY OF JULY 2020 AT 1:15 P.M. IN THE VILLASIS WATER DISTRICT BOARDROOM.

Supplemental Bid Bulletin No. 2020-02

After considering the queries, clarifications, recommendations and suggestions, the Bids and Awards Committee (BAC) hereby decides to include, revise, amend, delete and/or adapt the following:

Item No.	Query	BAC Response
1	What is the required pipeline specification to be used for the 100mm pipelaying works?	uPVC Pipes for Potable Water Supply, C-100 (Series 10) Eff. Length 6LM with Machine Installed Fixed Seal
2	Is the procurement timeline for the pipelaying project in Bacag West final? Particularly stated in Invitation to Bid (Bid Documents) No. 7 re: Advertisement on July 01-08, 2020 No. 9 re: Submission of Bids and No. 10 re: Bid Opening on July 22, 2020	Typographical Error July 01-15, 2020 as corrected Adjust Schedule due to unavailability of some BAC members July 23, 2020 as corrected The BAC decided to adjust the procurement timeline of the project as attached hereto.

All terms, conditions and instructions to bidders specified in the Bidding Documents inconsistent with this Bid Bulletin are hereby superseded and modified accordingly.


Please see attached document for your reference:

- Revised Procurement Timeline as of July 10, 2020
- Revised Technical Specifications as of July 10, 2020

For the information and guidance of all concerned.

Issued this Bid Supplement on the 10th day of July 2020.


RAMON FERDINAND R. ORDOÑEZ
BAC Chairperson



Republic of the Philippines
Region I - Province of Pangasinan

Villasis Water District

(075) 632-1093 / (075) 632-1080 / 09178615250
www.villasiswaterdistrict.gov.ph * villasis_wd@yahoo.com
CCC # 95 * Poblacion Zone I, Villasis, 2427

Procurement Timeline

As of July 10, 2020

Infrastructure Project – Pipelaying of 100mm Parallel Pipelines in Bacag West-Highway

Procurement Stage	Start Date	End Date
Advertisement:	07/01/2020	07/15/2020
Pre-bid Conference:	07/10/2020	07/10/2020
Submission of Bid:	07/23/2020	07/23/2020
Bid Evaluation:	07/24/2020	07/24/2020
Post Qualification:	07/27/2020	07/27/2020
Issuance of Notice of Awards:	07/28/2020	07/28/2020
Contract Preparation and Signing:	07/29/2020	07/29/2020
Approval by Higher Authority:	07/30/2020	07/30/2020
Notice to Proceed:	07/30/2020	07/30/2020

"Ditoy Villasis, Danum Nalinis"

BILL OF QUANTITIES

Villasis Water District Expansion of 100mm Parallel
pipelines
Bacag West, Villas, Pangasinan

A. Pipes

	Description	Quantity	Unit
1.	100mm uPVC Pipes for Potable Water Supply, C-100 (Series 10) Eff. Length 6LM with Machine Installed Fixed Seal	192	Pc

B. Concrete and Pavement Restoration

	Description	Quantity	Unit
1.	Concrete and Pavement Restoration	150	LM

C. Fittings and Accessories

	Description	Quantity	Unit
1.	Mechanical Coupling 4"	1	Pc
2.	Mechanical Coupling 3"	1	Pc
3.	Mechanical Elbow	3	Pc
4.	Mechanical Reducer 4"x3"	1	Pc
5.	Mechanical Gate Valve 4"	1	Pc
6.	Mechanical Tee 3"x3"x3"	1	Pc
7.	Mechanical Tee 4"x4"x4"	1	Pc
8.	Valve Box	1	Pc
9.	Valve Box	1	LS

D. Labor – Pipelaying 100mm uPVC

	Description	Quantity	Unit
1.	Excavation	1130	LM
2.	Pipe Fitting	192	Pc
3.	Back Filling	1130	LM
4.	Hydro Testing and Disinfection	1130	LM

E. Concrete Pavement Demolition and Restoration

	Description	Quantity	Unit
1.	Concrete Pavement Demolition and Restoration	150	LM

F. Installation of Fittings and Accessories

	Description	Quantity	Unit
1.	Installation of Fittings and Accessories	150	LM